

# T E S T   C E R T I F I C A T E

ST-11-02-07-01

**Product:** DPL-laminate floor covering, Product group 33, thickness 8 mm - 12 mm

**Customer:** Kronoflooring GmbH Lampertswalde/Dresden  
Mühlbacher Straße 1  
01561 Lampertswalde

**Order/  
Test method** External quality control of selected properties on a laminate floor covering  
according to EN 13329

**Test report:** 279268/1

**Test result:**


- The general requirements according to table 1 are fulfilled.
- The classification requirements of the following levels of use are fulfilled:

Resistance against abrasion:	classes 21 - 23, 31 - 34
Resistance against impact:	classes 21 - 23, 31 - 33
Resistance against staining:	classes 21 - 23, 31 - 34
Thickness swelling:	classes 21 - 23, 31 - 33
Resistance against soft chair rolls:	classes 21 - 23, 31 - 33
Resistance against movement of a furniture leg:	classes 21 - 23, 31 - 33

Dresden, 07 February 2011



Head of laboratory



Engineer in charge