

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-10-10-22-01

**Product:** Laminate floor covering "8 mm DPL Antistatic"  
(Product name of the producer)

**Manufacturer:** Kronoflooring GmbH  
Mühlbacher Straße 1  
01561 Lampertswalde

**Order:** Test of the electrostatic behaviour according to EN 14041:2008

**Test method:** Classification of the body voltage according to EN 1815:1997

**Test report:** No. 270325 from 22 October 2010

**Test result:** The measured body voltage at 23 °C / 25 % humidity were  $\leq 2$  kV.  
The laminate floor covering "8 mm DPL Antistatic" fulfils the criterions for the  
classification as an  
**"Antistatic Floor Covering"**  
in accordance with the European Standard EN 14041:2008.

Dresden, 22 October 2010



Head of laboratory



Engineer in charge