

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING


BOD-11-01-26-01

- Product:** Laminate floor coverings with the structures WG, RF, WF, SP, AS, BF, SU, BS
- Customer:** Kronoflooring GmbH Lampertswalde/Dresden
Mühlbacher Straße 1
01561 Lampertswalde
- Order:** Determination of the slippery resistance according to EN 13893 / classification according to EN 14041
- Test reports:** 265188
- Result:** The tested laminate floor coverings structures are fulfilling with the values of $\mu = 0,52 - 0,70$ the requirements of the class DS ($\mu \geq 0,3$) according to EN 14041 (CE-labelling).

Dresden, 26 January 2011



Head of laboratory



Engineer in charge