

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-11-05-26-01

Product: DPL-Laminate floor coverings in the thicknesses 6 mm - 12 mm

Producer: Kronoflooring GmbH
 Mühlbacher Str.1
 01561 Lampertswalde / Dresden

Order: Determination of a selected property according to EN 14041 (CE-labelling)

Test method: Determination of the fire resistance according to DIN EN ISO 9239-1,
 classification according to EN 13501-1

Test report: 279268/1


Test result:

Property / classification	Declaration according to EN 14041
Fire resistance according to EN ISO 9239-1, classification according to EN 13501-1	Fire class C _{fl} -s1

Dresden, 26 May 2011



Head of laboratory

Engineer in charge